

## Future Technology Devices International Limited Practical USB Interface Solutions

Unit1, 2 Seaward Place, Centurion Business Park, Glasgow G41 1HH, Scotland, United Kingdom

Tel: +44 (0)141 429 2777 Fax: +44 (0) 141 429 2758 E-Mail: sales1@ftdichip.com Web: http://www.ftdichip.com

## **Product Change Notification**

i i dadet enange itoenik	
FT-X series of ICs: FT200XD, FT201XS, FT201XQ, FT220XS, FT220XQ, FT221XS, FT221XQ, FT230XS, FT230XQ, FT231XS, FT231XQ, FT240XS, FT240XQ.	Estimated implementation date
FT-X series of devices revised from Revision B to Revision C	June 2012
FT-X devices will enter reset if operated with a specified supply input voltage of $+3.3V$ . The device is fully functional when operated at a supply voltage of VCC = $+5V$	
The +3.3V regulator does not function correctly at voltages below +4.6V. When the voltage falls below +4.6V all devices enter reset.	
Datasheets correctly indicate the devices should operate at VCC= +3.3V. The change will be recorded in an individual Technical Note errata for each of the FT-X series ICs.	
Operation at VCC=+3.3V	
Device date-code will be changed to a "C" to indicate Revision C. The date-code marked on the devices will change from YYWW-B to YYWW-C (where YY= year and WW= week of manufacture)	
June 2012	
Risk assessment: no risk of operation at +5V Fit: package dimensions are unchanged. Form: visual appearance is unchanged except for markings. Function: FT-X series will operate at specified supply of +3.3V	
http://www.ftdichip.com/Support/Documents/ProductChangeNotifications/PCN_FT_011.pdf	
	FT-X series of ICs: FT200XD, FT201XS, FT201XQ, FT220XS, FT220XQ, FT221XS, FT221XQ, FT230XS, FT230XQ, FT231XS, FT231XQ, FT240XS, FT240XQ.  FT-X series of devices revised from Revision B to Revision C  FT-X devices will enter reset if operated voltage of +3.3V. The device is fully fusupply voltage of VCC = +5V  The +3.3V regulator does not function con +4.6V. When the voltage falls below +4.6D at asheets correctly indicate the device +3.3V. The change will be recorded in errata for each of the FT-X series ICs.  Operation at VCC=+3.3V  Device date-code will be changed to a date-code marked on the devices will changed to a date-code marked on the devices will changed to a date-code marked on the devices will changed. C (where YY= year and WW= week of marked to a date-code marked on the devices will changed. Form: visual appearance is unchanged. Form: visual appearance is unchanged ex Function: FT-X series will operate at specific parts of the provious process.

## Others:

The revision B of the FT-X series is fully functional when operated at a supply voltage of +5V. The revision C will correct the operation of the +3.3V regulator.

The FT-X evaluation modules, UMFT201XA, UMFT220XA, UMFT221XA, UMFT230XA, UMFT231XA and UMFT240XA default to +5V operation. They can only be configured for +3.3V operation if fitted with associated revision C FT-X device.